


# *Characteristics and Various Applications of Vanadium Redox-Flow Battery (VRB)*


Background of the Development  
Principle  
Characteristics  
Various Applications

*SUMITOMO ELECTRIC INDUSTRIES, Ltd.*


# Vanadium Redox Flow Battery Development Program




# Principle of Vanadium Redox Flow Battery




# Construction of Cell Stack



Components of a cell



## Characteristic Advantage of VRB



## Various Applications of VRB

1. Load Leveling
2. UPS
3. Storage and Stabilization of Photovoltaic and Wind-Generated Electricity
4. Power Quality Control
  - Load Frequency Control (LFC)
  - Spinning Reserve
  - Stabilization of Flicker

## VRB Projects in Japan



### Awarded Projects

Place	Applications	Specifications	Start of operation
Office building	Load leveling (Demonstration)	100kW x 8h	2000/02
Semi-conductor factory	1) Voltage sag protection 2) Load leveling	1) 3000kW x 1.5sec. 2) 1500kW x 1h	2001/04
Wind power station	Stabilization of wind turbine output (Field test)	170kW x 6h	2001/04
Golf course	Load leveling (Photovoltaic hybrid system)	30kW x 8h	2001/04

# Application to Office Building

<b>Capacity</b>	<b>100kW-8h</b>
<b>Place</b>	<b>SEM, Osaka</b>
<b>Start of operation</b>	<b>February 2000</b>

<b>Battery module</b>	<b>25kW cell stack x 4</b>
<b>Tanks</b>	<b>350 ft<sup>3</sup> x 4</b>





## Carrying Rubber Tank to Manhole




**Manhole - 60cm dia. - was an only way into tank space.**

**Rubber tank was bound to a roll of 40cm dia.**

**No reconstruction of building was done for installation of rubber tank.**

# Load-Leveling Operation of 100kW VRB




# Application to Semi-Conductor Factory

## Specifications

Operation - First of April 2001

Function	Purpose	Output	Operation
(1) Voltage Sag Protection	Protection of Important Load	3MW x 1.5 sec	At the Occurrence of Voltage Sag 5 - 20 times /year
(2) Load leveling	Reduction of Electricity Charge	1.5MW x 1hour	Everyday


## System Layout




# Operation Sequence

## Load leveling (Normal operation)

### Charge




### Discharge




## UPS function

### Voltage sag protection



### Test result for voltage sag (0.5sec)



Grid System  
6.6kV


Load  
6.6kV

# Application to Wind Power Station (NEDO Project)

**Purpose - Field test for stabilizing  
of output**

**Spec. - 170kW×6h**

Commission Order  
NEDO → IAE → SEI  
(The Institute of Applied Energy)



01/4/F ~ 9/E Field test

~ 02/2/E


Data analysis

## Appearance of VRB and Wind Turbine

Place : Tomari Wind Hills of Hokkaido Electric Power Co.,Inc.

Wind Turbine : 250 kW

VRB : 170 kW-6h



# VRB Equipment

Battery Cubicle



AC/DC Converter



Electrolyte Tank




# Field Test for Stabilization of WT Output

## <Operation Outline>

Target of total output (t) = Average of WT output [(t-Δt) ~ t]


VRB output (t) = Target of total output (t) - WT output (t)

(+ : Discharge, - : Charge)





## Example of Simulation Results for Stabilization of WT Output



# Field Test for Effective Utilization of WT Output

## <Method>


VRB is charged by WT output when demand is low, and  
VRB is discharged when demand is high.

## <Operation>

Target of total output is set up considering the demand in advance.

$$\text{VRB output} = \text{Target of total output} - \text{WT output}$$

## <Example of simulation results>



# Application to Golf Course

(Hybrid System of VRB and Photovoltaic Generation System)

## <Specifications>

Load leveling of DC load in golf course




( Light in club house)

30kW×8h

## <Schedule>

Operation → First of April 2001

## <System Diagram>



# Power Quality Control

## Purpose

1. Load Frequency Control (LFC)
2. Spinning Reserve
3. Stabilization of Flicker

Presentation in IEEE PES Winter Meeting ('01/1/28~'01/2/1)  
by Kansai Electric Power Co., Inc.

Basic data collected by the experiment of 1kW (1kWh) VRB.  
Simulation results of VRB utilization for power quality.